# **CONSOLE**



## **CONSOLE MONOSPLIT AIR CONDITIONER**

The new Hokkaido console indoor unit has been designed to ensure maximum functionality combined with a pleasant and modern appearance. Thanks to the diversified air flows, these indoor units allow you to obtain a pleasant temperature inside the room.

### **OPERATION**

-15~**52°**C

 $-15^{\sim}24^{\circ}C$ 

### **PERFORMANCE & INCENTIVES**

MODEL	SEER	SCOP	ECO BONUS*	BONUS CASA*	CONTO TERMICO 2.0*
3.50 kW	7.50	4.10	~	<b>~</b>	<b>~</b>
4.70 kW	6.80	4.10	~	~	<b>~</b>

<sup>\*</sup> For Italian market only.

#### **RESIDENTIAL & COMMERCIAL R32**

# HFIDM 350-530 ZAL





Remote control included



-15~52°C in cooling

Double air flow, upper and lower

-15~24° C in heating

Double installation option, floor-mounted or wall-mounted

ndoor unit model			HFIDM 350 ZAL	HFIDM 530 ZAL	
Outdoor unit model			HCKDS 350 ZA	HCKDS 530 ZA	
ype				er heat pump	
Control (supplied)			Remote control		
Vi-Fi module			Integrated		
Vominal data			· · · ·	gracea	
Nominal capacity (T=+35°C)		kW	3.50 (1.35~4.40)	4.70 (1.53~5.60)	
lominal absorbed power (T=+35°C)	Cooling	kW	1.03 (0.26~1.60)	1.45 (0.47~2.30)	
Nominal energy efficiency coefficient	Cooming	EER1	3.40	3.24	
lominal capacity (T=+7°C)		kW	3.50 (1.24~5.30)	5.00 (1.40~6.20)	
lominal absorbed power (T=+7°C)	Heating	kW	0.94 (0.19~1.51)	1.34 (0.46~2.25)	
lominal energy performance coefficient		COP1	3.72	3.73	
easonal data		COI	J.7 E	5.75	
heoretical load (Pdesignc)		kW	3.50	5.00	
easonal energy efficiency index		SEER1	7.50	6.80	
easonal energy efficiency class	nal energy efficiency class  Cooling		A++	A++	
Annual energy consumption		626/2011 <sup>3</sup> kWh/y	162	257	
heoretical load (Pdesignh) @ -10°C		kW	2.70	3.70	
Seasonal energy efficiency index	Heating (average	SCOP2	4.10	4.10	
easonal energy efficiency class	weather conditions)	626/20113	A+	A+	
Annual energy consumption	weather conditions)	kWh/y	923	1261	
Electrical data		KTVII/ y	725	1201	
ower supply	Outdoor unit	Ph-V-Hz	1Ph - 220	1Ph - 220/240V - 50Hz	
ower sable	Outdoor driit	Type	3 x 2.5 mm <sup>2</sup>	3 x 2.5 mm <sup>2</sup>	
Viring between I.U. and O.U.		no.	4	4	
	Cooling	A A	4.50 (1.10~7.00)	6.30 (2.00~10.00)	
lominal absorbed electric current	Heating	A	4.10 (0.80~6.60)	5.80 (2.00~9.80)	
Max current		A	9.00	12.00	
Max absorbed power		kW	1.70	2.40	
Refrigerant circuit data		KVV	1.70	2.10	
Refrigerant <sup>4</sup>		Type (GWP)	R32	(675)	
).ty of refrigerant pre-charge		Kg	0.78	1.03	
Tons of CO2 equivalent		t	0.527	0.695	
iguid/gas refrigerant pipe diameter		mm (inches)	6.35(1/4") / 12.74(1/2")	6.35(1/4") / 12.74(1/2")	
Max split length		m m	25	30	
Max difference in height U.I./U.E.		m	10	20	
plit length without additional charge		m	5	5	
Additional charge		g/m	30	30	
ndoor unit specifications		9/111	30		
Dimensions	LxDxH	mm	700x225x600	700x225x600	
let weight	LADAII	Kg	15	15	
ound power level	Hi	dB(A)	52	56	
ound pressure level	Hi/Mi/Lo	dB(A)	42/39/36	44/40/37	
reated air volume	Hi/Mi/Lo	m3/h	600/530/430	650/550/450	
Outdoor unit specifications	T II/ IVII/ LU	1112/11	007 0000	0.04-100-0.00	
Dimensions	LxDxH	mm	709x280x536	785x300x555	
Net weight		Kg	23	29	
Sound power level		dB(A)	64	65	
Sound pressure level		dB(A)	64 54	55	
reated air volume	Max		2000	2600	
reaten all voluffle		m³/h °C			
perating limits (outdoor temperature)	Cooling	°(		5~24	
<u> </u>	Heating	L	-13	)~Z <del>4</del>	
Optional parts					

1. Value measured according to the harmonised standard EN14511, 2. EU Regulation No. 206/2012 - Value measured according to the harmonised standard EN14825, 3. EU Delegated Regulation No. 626/2011 on the new energy consumption labelling of air conditioners. 4. Refrigerant leakage contributes to climate change. When released into the atmosphere, refrigerants with a lower global warming potential (GWP) contribute less to global warming than those with a higher GWP. This appliance contains a refrigerant with a GWP of 675. Therefore, if 1 kg of this refrigerant were released into the atmosphere, the impact on global warming would be 675 times higher than 1 kg of CO2, over a period of 100 years. Under no circumstances should the user attempt to intervene on the refrigerant circuit or disassemble the product. In case of need, always contact qualified personnel.

